

HONOLULU FIRE DEPARTMENT
CITY AND COUNTY OF HONOLULU

636 South Street
Honolulu, Hawaii 96813-5007
Phone: 808-723-7139 Fax: 808-723-7111 Internet: www.honolulu.gov/hfd

KIRK CALDWELL
MAYOR



MANUEL P. NEVES
FIRE CHIEF

LIONEL CAMARA JR.
DEPUTY FIRE CHIEF

January 11, 2018

Mr. Ronald Sato, AICP, Senior Associate
HHF Planners
733 Bishop Street, Suite 2590
Honolulu, Hawaii 96813

Dear Mr. Sato:

Subject: Hawaiian Memorial Park Cemetery Expansion Project
Kaneohe, Hawaii
Tax Map Key: 4-5-033: 001 (Portion)

2018 JAN 16 A 9:26
LAND USE COMMISSION
STATE OF HAWAII

In response to your letter dated December 19, 2017, regarding the abovementioned subject, the Honolulu Fire Department (HFD) reviewed the material provided and requires that the following be complied with:

1. Fire department access roads shall be provided such that any portion of the facility or any portion of an exterior wall of the first story of the building is located not more than 150 feet from fire department access roads as measured by an approved route around the exterior of the building or facility. (National Fire Protection Association [NFPA] 1; Uniform Fire Code [UFC]TM, 2012 Edition, Sections 18.2.3.2.2 and 18.2.3.2.2.1.)

A fire department access road shall extend to within 50 feet of at least one exterior door that can be opened from the outside and that provides access to the interior of the building. (NFPA 1; UFCTM, 2012 Edition, Section 18.2.3.2.1.)

2. A water supply approved by the county, capable of supplying the required fire flow for fire protection, shall be provided to all premises upon which facilities or buildings, or portions thereof, are hereafter constructed, or moved into or within the county. When any portion of the facility or building is in excess of 150 feet from a water supply on a

Mr. Ronald Sato
Page 2
January 11, 2018

fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided when required by the AHJ [Authority Having Jurisdiction]. (NFPA 1; UFC™, 2012 Edition, Section 18.3.1, as amended.)

3. The unobstructed width and unobstructed vertical clearance of a fire apparatus access road shall meet county requirements. (NFPA 1; UFC™, 2012 Edition, Sections 18.2.3.4.1.1 and 18.2.3.4.1.2, as amended.)
4. Submit civil drawings to the HFD for review and approval.

Should you have questions, please contact Battalion Chief Wayne Masuda of our Fire Prevention Bureau at 723-7151 or wmasuda@honolulu.gov.

Sincerely,



SOCRATES D. BRATAKOS
Assistant Chief

SDB/TC:jl

cc: Scott Derrickson, Land Use Commission
State of Hawaii

POLICE DEPARTMENT
CITY AND COUNTY OF HONOLULU

801 SOUTH BERETANIA STREET · HONOLULU, HAWAII 96813
TELEPHONE: (808) 529-3111 · INTERNET: www.honolulu-pd.org



KIRK CALDWELL
MAYOR

SUSAN BALLARD
CHIEF

JOHN D. MCCARTHY
JONATHAN GREMS
DEPUTY CHIEFS

OUR REFERENCE MT-AL

January 11, 2018

Mr. Ronald A. Sato, AICP
HHF Planners
Pacific Guardian Center
733 Bishop Street, Suite 2590
Honolulu, Hawaii 96813

Dear Mr. Sato:

This is in response to a letter from HHF Planners, dated December 19, 2017, requesting comments on a Draft Environmental Impact Statement, for the Hawaiian Memorial Park Cemetery Expansion project.

The Honolulu Police Department has reviewed this project and has concerns regarding the safe flow of traffic at the project site.

We recommend that the developer evaluate the outcome of the traffic flow affected by the construction vehicles commuting to the project site. We also recommend that the developer provide a traffic mitigation plan to implement traffic controls and management (e.g., flag persons, clear signage and cones, special duty officers, etc.) for construction vehicles driving to and from the work site. These recommendations will ensure a safe means of ingress/egress for construction vehicles, motorists, and pedestrians in the vicinity.

Additionally, the contractor should obtain the necessary street usage permits from the Department of Transportation, State of Hawaii, for the purposes of parking and transporting any construction equipment around the vicinity of the project area.

If there are any questions, please call Major Crizalmer Caraang District 4 (Kailua-Kaneohe-Kahuku) at 723-8639.

Thank you for the opportunity to review this project.

Sincerely,

A handwritten signature in black ink, appearing to read "Mark Tsuyemura".

MARK TSUYEMURA
Management Analyst VI
Office of the Chief

cc: ✓ Mr. Scott Derrickson
Land Use Commission

Serving and Protecting With Aloha

2018 JAN 16 A 9:26
LAND USE COMMISSION
STATE OF HAWAII