

HONOLULU FIRE DEPARTMENT  
**CITY AND COUNTY OF HONOLULU**

636 South Street  
Honolulu, Hawaii 96813-5007  
Phone: 808-723-7139 Fax: 808-723-7111 Internet: www.honolulu.gov/hfd

KIRK CALDWELL  
MAYOR



MANUEL P. NEVES  
FIRE CHIEF

LIONEL CAMARA JR.  
DEPUTY FIRE CHIEF

September 24, 2018

Mr. Ronald Sato, AICP  
Senior Associate  
HHF Planners  
Pacific Guardian Center  
733 Bishop Street, Suite 2590  
Honolulu, Hawaii 96813

LAND USE COMMISSION  
STATE OF HAWAII

2018 OCT -1 A 8:33

Dear Mr. Sato:

Subject: Draft Environmental Impact Statement  
Hawaiian Memorial Park Cemetery Expansion Project  
Kaneohe, Hawaii  
Tax Map Key: 4-5-033: 001 (Portion)

In response to your letter dated September 8, 2018, regarding the abovementioned subject, the Honolulu Fire Department (HFD) requires that the following be complied with:

1. Fire department access roads shall be provided such that any portion of the facility or any portion of an exterior wall of the first story of the building is located not more than 150 feet from fire department access roads as measured by an approved route around the exterior of the building or facility. (National Fire Protection Association [NFPA] 1; 2012 Edition, Sections 18.2.3.2.2 and 18.2.3.2.2.1.)

A fire department access road shall extend to within 50 feet of at least one exterior door that can be opened from the outside and that provides access to the interior of the building. (NFPA 1; 2012 Edition, Section 18.2.3.2.1.)

2. A water supply approved by the county, capable of supplying the required fire flow for fire protection, shall be provided to all premises upon which facilities or buildings, or portions thereof, are hereafter


Mr. Ronald Sato, AICP  
Page 2  
September 24, 2018

constructed, or moved into or within the county. When any portion of the facility or building is in excess of 150 feet from a water supply on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided when required by the AHJ [Authority Having Jurisdiction]. (NFPA 1; 2012 Edition, Section 18.3.1, as amended.)

3. The unobstructed width and unobstructed vertical clearance of a fire apparatus access road shall meet county requirements. (NFPA 1; 2012 Edition, Sections 18.2.3.4.1.1 and 18.2.3.4.1.2, as amended.)
4. Submit civil drawings to the HFD for review and approval.

Should you have questions, please contact Battalion Chief Wayne Masuda of our Fire Prevention Bureau at 723-7151 or [wmasuda@honolulu.gov](mailto:wmasuda@honolulu.gov).

Sincerely,



SOCRATES D. BRATAKOS  
Assistant Chief

SDB/TC:bh

cc: Scott Derrickson, State of Hawaii  
Land Use Commission