Miki Basin Industrial Park Environmental Assessment

Exhibit H

Wastewater Master Plan

PŪLAMA LĀNA'I MIKI BASIN

200 ACRE INDUSTRIAL PARK

Lana'i, Hawai'i

WASTEWATER MASTER PLAN

Akinaka & Associates, Ltd. 1100 Alakea Street, Suite 1800 Honolulu, Hawaii 96813 Prepared By:

Date: February 2019

TABLE OF CONTENTS

- INTRODUCTION <u>_</u>:
- EXECUTIVE SUMMARY =i
- **EXISTING WASTEWATER SYSTEM** ≡
- LAND USE ≥
- WASTEWATER FLOW STANDARDS 1. Design Flows >
- INDUSTRIAL PARK WASTEWATER DEMAND ž
- PROPOSED WASTEWATER SYSTEM ,≓
- COST CONSIDERATIONS ∠III
- EXHIBITS ×
- -.
- Exhibit 1: Vicinity Map Exhibit 2: Proposed Land Use Exhibit 3: Wastewater Flow Summation
- REFERENCES ×
- .-
- County of Maui, Wastewater Reclamation Division. Wastewater Flow Standards. February 2, 2006. City and County of Honolulu, Department of Wastewater Management. Design Standards of the Department of Wastewater Management Volume 1. July 1993 с,

INTRODUCTION

_

The Wastewater Master Plan for Pūlama Lāna'i Miki Basin 200-Acre Industrial Park provides the basic information for the design of the wastewater treatment system for the Miki Basin 200-Acre Industrial Park, herein referred to as the "Industrial Park", based on zoning requirements. The purpose of the master plan is to identify the projected wastewater flows from the development. The Miki Basin 200 Acre Industrial Park consists of approximately 200 acres of agricultural zoned lands. Pulama Lāna'i is in the process of rezoning the area for light and heavy industrial lands. The project area is located directly south of Lana'i Airport within the Palawai Irrigation Grid (see **Exhibit 1: Location Map**). The majority of the proposed Industrial Park is currently undeveloped with the exception of the Maui Electric Company (MECO) Miki Basin substation and a portion of the 20-acre approved subdivision which is currently used by Pulama Lāna'i. Pulama Lāna'i is in the process of finalizing condominium documents for the 20-acre subdivision has not been established.

II. EXECUTIVE SUMMARY

There is currently no existing County or privately owned or operated wastewater treatment system in the vicinity of Miki Basin. The construction of onsite Individual Wastewater Systems (IWS), decentralized Wastewater Treatment Plants (WWTP) and collection systems will be required to support development activity.

Since development plans for the Industrial Park are not yet available, proposed wastewater flows for buildout of the Industrial Park is based on the proposed land use and an estimated developable area for each parcel. The developable area of each parcel estimates that up to 70 percent of the total parcel area will generate wastewater flows; the remaining 30 percent will consist of areas with no wastewater flows such as roads and parking areas. The proposed average wastewater flow for full buildout of the Industrial Park is 365,904 gpd.

III. EXISTING WASTEWATER SYSTEM

There is currently no existing County or privately owned or operated wastewater treatment system in the vicinity of Miki Basin. Wastewater is currently treated via onsite individual wastewater systems (IWS). WASTEWATER FEBRUARY 2019

LAND USE

≥

Pulama Lāna'i is in the process of rezoning approximately 200 acres of land from agriculture to light and heavy industrial as shown in **Exhibit 2: Proposed Land Use**:

100 ac	100 ac	200 ac
10(10(20(
=	ial	
nt Industria	avy Industr	al
Ligh	He	Tot

This conceptual plan is intended to provide a basis for the design of the wastewater system and may not reflect the final development densities. Since development plans for the Industrial Park are not yet available, proposed wastewater flows for buildout of the Industrial Park is based on the proposed land use and an estimated developable area for each parcel. The developable area of each parcel estimates that up to 70 percent of the total parcel area will generate wastewater flows; the remaining 30 percent total consist of areas with no wastewater flows; the remaining 30 percent areas.

V. WASTEWATER FLOW STANDARDS

As outlined in the County of Maui's Wastewater Flow Standards and the Design Standards of the Department of Wastewater Management, the following criteria are used in determining the minimum requirements for the wastewater system.

1. Design Flows

- For planning purposes, flows are based on estimated occupancy as determined by the standards.
- b. The unit flows for the various land uses are as follows:

Land Use	Unit	Average Flows
Factory	Employee	30 30
Industrial Shop	Employee	25
Laundry (coin operated)	Machine	300
Office	Employee	20
Storage, w/offices	Employee	15
Storage w/ offices and	Employee	30
showers		

WASTEWATER FEBRUARY 2019

5		
nse		
Store Customer bathroom	usage	

The following standards were used to compute the minimum number of units required per land use type:

Office Employees	1 per 200 square feet of floor
	area
Retail Warehouse Employees	1 per 350 square feet of floor
	area
Storage/Industrial Employees	1 per 500 square feet of floor
	area

VI. INDUSTRIAL PARK WASTEWATER FLOWS

Since site layouts, land uses and unit densities for each parcel are not yet determined, wastewater flows were based on the minimum number of units required by land use type. Since the majority of onsite flows will be generated by employees, the industrial activity with the highest average flow for employees, factory, was used to estimate wastewater flows. Based on the proposed land use, the proposed average flow for full buildout of the Industrial Park is 365,904 gpd (see Exhibit 3: Wastewater Flow Summation).

VII. PROPOSED WASTEWATER SYSTEM

Since there is no existing wastewater treatment system in the vicinity of the Industrial Park, wastewater flows within the Industrial Park will be treated by onsite IWS systems and decentralized WWTPs. These systems are ideal for areas that are remote and have factors that can make tying into an existing wastewater system difficult or infeasible. Each development within the Industrial Park will be required to provide its own wastewater treatment system and associated wastewater collection system. The type of treatment system used will be determined by the size and type of development.

Onsite IWS systems and decentralized WWTPs are regulated by the Department of Health (DOH) under Chapter 62 of Title 11, Hawaii Administrative Rules (HAR). Under Subchapter 3 of the rules, IWS systems can be used as a temporary onsite means of wastewater disposal in lieu of a wastewater treatment works under the following conditions: WASTEWATER FEBRUARY 2019

- There is 10,000 square feet of land area for each individual wastewater system;
 - The total wastewater flow of the development does not exceed 15,000 apd:

с,

- 3. Area of the lot is not less than 10,000 square feet; and
- The total wastewater flow into each individual wastewater system will not exceed one thousand gallons per day.

Multiple IWS systems may be used provided that the building is owned by one person. At DOH's discretion, multiple buildings may connect to one IWS system provided that the buildings are located on the same lot and generate wastewater of similar strength and character. IWS are required to consist of a septic tank and soil absorption system, sand filter, subsurface irrigation system or other treatment unit as approved by DOH. Cesspools are prohibited as adequate treatment is not provided.

Where developments do not meet the requirements for an IWS system, decentralized WWTPs are recommended. WWTPs can be sized to accommodate flows from multiple properties located in the same general area. Depending on the development timeline, construction of the WWTP can be phased such that the system can be adapted and expanded to accommodate additional flows at a later date. WWTPs should be located in the lowest region of the service area to allow for gravity flow into the WWTP and avoid the use of pump stations and force mains.

VIII. COST CONSIDERATIONS

Since site layouts are not yet available, budgetary costs for development of the Industrial Park could not be determined. General costs for the various improvements are as follows:

Sewer Pipe, PVC

\$200 per linear foot	\$250 per linear foot	\$325 per linear foot
8-inch sewer pipe	10-inch sewer pipe	15-inch sewer pipe

WASTEWATER FEBRUARY 2019


Treatment Systems IVVS, Septic tank with \$ 26,500 – 66,000 / 1,000 gallons absorption trenches WWTP (1,000 to 10,000 gpd) \$ 31,000 – 88,000 / 1,000 gallons

\$ 68,000 - 125,200 / 1,000 gallons

WWTP

WASTEWATER FEBRUARY 2019

EXHIBITS



706'S9E	Total							
64,033	30	5,134	0ZZ'290'T	24.5	32	Light Industrial	Light Industrial	B-1
785'95S	30	860'9	3'046'500	02	00T	leirtzubnl yve9H	leintsubni yvesH	2-4/4-A
616,811	30	796' £	086'ī86'ī	S.24	S9	Light Industrial	Light Industrial	E-A\2-A\1-A
(GPD)	(Sbqc)	(1 per 500 SF)	(fz)	(၁၉)	(၁၉)			
wolii gvA	Per Capita	səəkolqm3	691A	¹ 691A Building	БэтА	esU bnsJ	Description	Point No
	wola ylisQ gvA	Required		-				
		betemite3						
	200 АСКЕ ІИДИЗТЯІАL РАЯК							
	VIZAB IXIN I VANĀJ AMALŪP							
NOITAMMU2 WOJT 9: TURIHX3								

sere letot fo %0T to themoplaveb guiblind betemitse no besed $^{\scriptscriptstyle 1}$

8102/21/21